

HANKOOK FIRE FIGHTING EQUIPMENTS CO., LTD.

#33, PYEONGRIRO29-Gil, SEO-Gu, DAEGU, KOREA

Tel. : +82-53-854-9994 / Fax. : +82-53-854-9518

CERTIFICATE OF QUALITY & QUANTITY

Customer : **VIETNAM LABOUR PROTECTION JOINT STOCK COMPANY**

Item / Description : Fire extinguisher 3.3kg ABC

Model : HK-3.3

Contract : 01 Kfire / VLP

This is to CERTIFY that the suppliers detailed hereon have been inspected and tested in accordance with the requirements indicate unless otherwise stated, conformed in all respects to the relevant drawings and specifications. Hydrostatic test, physical examination, paint, visual inspection, dimensional inspection and other test were made in the presence of the inspector, all material certificates and test results were found to be in compliance with the relevant requirements of the inspections and records.

No.	Item	Name Commodity & Specification	Quantity	Manufacturer
1	Fire extinguisher 3.3KG ABC Model : HK-3.3	ABC - 3.3KG	1,000pcs	Kfire

Criteria and specifications on the fire extinguishers are as follows:

SPECIFICATION	
TYPE	Dry Chemical Extinguisher Agent(ABC)3.3kg (N ₂ Stored-Pressure Type, Steel Container)
Model No.	HK-3.3
TYPE Approval No.	수소 15-18
Total Weight	5.2kg
Agent Weight	3.3kg
Major Agent	Mono Ammonium Phosphate (NH ₄ H ₂ PO ₄)
A Range of Operating Temperature	-20°C ~ 60°C
Test Pressure	1.92MPa(19.58kgf/cm ²)
Discharge Time	15sec
Discharge Range	4~6m
Classification	A:3, B:5, C

HANKOOK FIRE FIGHTING EQUIPMENTS CO., LTD.

HANKOOK FIRE-FIGHTING EQUIP.CO.,LTD.

S. H. JUNG

S. H. JUNG / PRESIDENT

정우경

